



**THE CITY OF MENTOR FIRE DEPARTMENT  
8467 CIVIC CENTER BLVD, MENTOR, OH 44060**

B&C Zoning  
3855 South Boulevard Street  
Suite 500  
Edmond, OK 73013

January 7, 2006

Re: 20060000/Site 65

To Whom It May Concern:

Two Fire code violations are active at 1032 Springside Boulevard. The South door exit light does not illuminate and a box was found in front of the electrical panel. A re-inspection will occur in 30 days.

Tony Wilkerson, Inspector  
The City of Mentor Fire Department